



# Building a photomultiplier tube testing lab and measuring dark rate

Suffolk County Community College  
and Brookhaven National Lab



## Lab Setup

- Dark box set up to hold four Photomultiplier tubes simultaneously and output signals
- Three step data collection
  1. Discriminator
  2. Delay Generator
  3. Visual Scalar
- Labview collects and files data and Oscilloscope shows signal outputs from PMTs




## Wiring

**Discriminator:** The PMTs constantly output a signal (Dark current) regardless of whether or not it detected a photon. The discriminator sets a voltage that has to be exceeded for the signal to pass through.

**Delay Generator:** The delay generator receives the input from the discriminator and outputs to the visual scaler. When active, the delay generator allows the signal to pass through, but only for a set period of time.

**Visual Scaler:** The visual scaler receives the output from the delay generator and outputs the number of signals it receives.



Lights On Channel 3												
Voltage	2000.00		2100.00		2200.00		2300.00		2400.00		2500.00	
Trial	Count	Rate	Count	Rate	Count	Rate	Count	Rate	Count	Rate	Count	Rate
1	155.00	12.92	852.00	71.00	2968.00	247.33	7140.00	595.00	16352.00	1362.67	49998.00	4166.50
2	134.00	11.17	872.00	72.67	2893.00	241.08	7048.00	587.33	16666.00	1388.83	50143.00	4178.58
3	146.00	12.17	918.00	76.50	2902.00	241.83	6894.00	574.50	16440.00	1370.00	50757.00	4229.75
4	113.00	9.42	922.00	76.83	2857.00	238.08	7015.00	584.58	17048.00	1420.67	49908.00	4159.00
5	134.00	11.17	884.00	73.67	2910.00	242.50	6996.00	583.00	16743.00	1395.25	49817.00	4151.42
6	140.00	11.67	917.00	76.42	2871.00	239.25	7092.00	591.00	17128.00	1427.33	49708.00	4142.33
Average	137.00	11.42	894.17	74.51	2900.17	241.68	7030.83	585.90	16729.00	1394.13	50055.17	4171.26
Error	8.57	0.71	14.29	1.19	22.66	1.89	50.21	4.18	158.40	13.20	214.13	17.84


  

Lights Off Channel 3												
Voltage	2000.00		2100.00		2200.00		2300.00		2400.00		2500.00	
Trial	Count	Rate	Count	Rate	Count	Rate	Count	Rate	Count	Rate	Count	Rate
1	126.00	10.50	913.00	76.08	2813.00	234.42	6834.00	569.50	16655.00	1387.92	49666.00	4138.83
2	126.00	10.50	921.00	76.75	3013.00	251.08	6923.00	576.92	16944.00	1412.00	49944.00	4162.00
3	152.00	12.67	870.00	72.50	2854.00	237.83	6982.00	581.83	16369.00	1364.08	49260.00	4105.00
4	126.00	10.50	859.00	71.58	2773.00	231.08	7038.00	586.50	16638.00	1386.50	49585.00	4132.08
5	144.00	12.00	877.00	73.08	2848.00	237.33	7035.00	586.25	16612.00	1384.33	49510.00	4125.83
6	106.00	8.83	840.00	70.00	2872.00	239.33	7160.00	596.67	16914.00	1409.50	49468.00	4122.33
Average	130.00	10.83	880.00	73.33	2862.17	238.51	6995.33	582.94	16688.67	1390.72	49572.17	4131.01
Error	9.39	0.78	16.53	1.38	48.99	4.08	66.54	5.55	117.37	9.78	139.62	11.64

## Dark Box “light tight” testing

- The first problem we encountered with the dark box was there was there was a measureable difference in counts when testing with the lights on vs. the lights off. This meant that the box wasn’t completely sealed
- We taped any visible weaknesses in the box and added a layer of foam tape between the box and the lid
- We tested the modified box at several different voltages with the lights both on and off and the differences were negligible
- The data is plotted above, the **red** line represents the data collected with the lights on and the **black** line represents the data with the lights off

<b>Lights On Channel 3</b>												
Voltage	2000.00		2100.00		2200.00		2300.00		2400.00		2500.00	
Trial	Count	Rate	Count	Rate	Count	Rate	Count	Rate	Count	Rate	Count	Rate
1	155.00	12.92	852.00	71.00	2968.00	247.33	7140.00	595.00	16352.00	1362.67	49998.00	4166.50
2	134.00	11.17	872.00	72.67	2893.00	241.08	7048.00	587.33	16666.00	1388.83	50143.00	4178.58
3	146.00	12.17	918.00	76.50	2902.00	241.83	6894.00	574.50	16440.00	1370.00	50757.00	4229.75
4	113.00	9.42	922.00	76.83	2857.00	238.08	7015.00	584.58	17048.00	1420.67	49908.00	4159.00
5	134.00	11.17	884.00	73.67	2910.00	242.50	6996.00	583.00	16743.00	1395.25	49817.00	4151.42
6	140.00	11.67	917.00	76.42	2871.00	239.25	7092.00	591.00	17128.00	1427.33	49708.00	4142.33
Average	137.00	11.42	894.17	74.51	2900.17	241.68	7030.83	585.90	16729.00	1394.13	50055.17	4171.26
Errorr	8.57	0.71	14.29	1.19	22.66	1.89	50.21	4.18	158.40	13.20	214.13	17.84
<b>Lights Off Channel 3</b>												
Voltage	2000.00		2100.00		2200.00		2300.00		2400.00		2500.00	
Trial	Count	Rate	Count	Rate	Count	Rate	Count	Rate	Count	Rate	Count	Rate
1	126.00	10.50	913.00	76.08	2813.00	234.42	6834.00	569.50	16655.00	1387.92	49666.00	4138.83
2	126.00	10.50	921.00	76.75	3013.00	251.08	6923.00	576.92	16944.00	1412.00	49944.00	4162.00
3	152.00	12.67	870.00	72.50	2854.00	237.83	6982.00	581.83	16369.00	1364.08	49260.00	4105.00
4	126.00	10.50	859.00	71.58	2773.00	231.08	7038.00	586.50	16638.00	1386.50	49585.00	4132.08
5	144.00	12.00	877.00	73.08	2848.00	237.33	7035.00	586.25	16612.00	1384.33	49510.00	4125.83
6	106.00	8.83	840.00	70.00	2872.00	239.33	7160.00	596.67	16914.00	1409.50	49468.00	4122.33
Average	130.00	10.83	880.00	73.33	2862.17	238.51	6995.33	582.94	16688.67	1390.72	49572.17	4131.01
Error	9.39	0.78	16.53	1.38	48.99	4.08	66.54	5.55	117.37	9.78	139.62	11.64



# Dark Current

- PMTs constantly output a very low signal whether or not they have detected a photon. This is called the Dark current.
- When analyzing data collected by the tubes, the dark rate has to be accounted for.

$N_\gamma$	Number of photons incident on photocathode
$N_{pe}$	Number of photoelectrons emitted by photocathode
$QE = N_{pe}/N_\gamma$	Quantum efficiency of PMT
$N_e$	Number of electrons emitted by anode
$g = N_e/N_{pe}$	Gain of PMT
$e = 1.6 \times 10^{-19} \text{C}$	electron charge
$Q =$	Charge emitted by anode
$I =$	Photocurrent emitted by anode
$I_D$	Dark Current emitted by anode

### Signal over noise: minimum light detection and PMT dark current

The minimum amount of light detectable by a PMT is determined by its dark current, gain, and quantum efficiency; in order for the PMT anode output to be above its dark current :

$$I = \frac{\Delta Q}{\Delta t} = \frac{N_e e}{\Delta t} = \frac{N_{pe} g e}{\Delta t} = \frac{N_\gamma Q E g e}{\Delta t} > I_D,$$

thus:

$$\frac{N_\gamma}{\Delta t} > \frac{I_D}{Q E g e};$$

for energy per photon at a given wavelength, the incident light power on the photocathode should be:

$$P = \frac{N_\gamma}{\Delta t} \frac{hc}{\lambda} > \frac{I_D}{Q E g e} \frac{hc}{\lambda};$$

for violet light at  $\lambda = 420 \text{ nm}$ , and a PMT with  $I_D = 100 \text{ nA}$ ,  $QE = 0.2$ ,  $g = 2.5 \times 10^6$ , the incident light power required for detection is:

$$P_{\text{required}} > \frac{100 \times 10^{-9} \text{A}}{0.2 (2.5 \times 10^6) (1.6 \times 10^{-19} \text{C})} \frac{(6.6 \times 10^{-34} \text{ m}^2 \text{kg/s}) 2.99 \times 10^8 \text{ m/s}}{420 \times 10^{-9} \text{m}}$$



# Generating the Signal and measuring gain

- The PMTs are to be tested by flashing a very dim LED light in the dark box with them.
- The LED is activated using the lowest possible voltage to emit the smallest number of photons possible.
- The light flashes very quickly (at roughly 10 Hz) and remains lit for only 11ns at a time.
- Using LabVIEW, we will measure data over the course of 20,000 pulses and use this data to calculate the gain of the PMTs.
- The gain of each PMT is the number of electrons that are emitted for the detection of a single photon.

# Quantum Efficiency

- The Quantum Efficiency is the likelihood of a photon having enough energy to trigger a signal output
- PMT sensitivity is measured in Amps per Watt (A/W), which is the measure of current output per Watt of light that impacts the photocathode

